

**ANALOGUE OUTPUT SIGNALS**

OUT.CLAMP	OUTPUT	
12 13	1	OZONE 1
14 15	2	OZONE 2 / pH
16 17	3	AR.AVERAGE/CONTROLLER 2
18 19	4	CONTROLLER 1


**ANALYZER - PROBE CONNECTIONS**

INPUT.CLAMP	MOZ66	PROBE		
20	INPUT 1	20	OZONE 1	PROBE 1
21	INPUT 1	19	OZONE 1	
22	INPUT 2	20	OZONE 2	PROBE 2
23	INPUT 2	19	OZONE 2	


**ANALYZER - PROBE CONNECTIONS, OZONE AND pH MEASUREMENT**

INPUT.CLAMP	MOZ66	PROBE		
20	INPUT 1	20	OZONE 1	PROBE 1
21	INPUT 1	19	OZONE 1	
22	INPUT 2	20	pH	PROBE 2
23	INPUT 2	19	pH	
6	CLEANING	17a	CLEANING	PROBE 1,2
7	CLEANING	18a	CLEANING	PROBE 1,2

**OZONE MEASUREMENT**



**pH MEASUREMENT (TEMPERATURE USED FOR COMPENSATION ONLY)**



z	GREEN
č	BLACK
b	WHITE
r	RED
me	MAIN ELECTRODE
re	REFERENCE ELECTRODE